

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2020/SZ/125

Dated: 18/03/2020

FIRE SAFETY CERTIFICATE


Certified that the Rao Ganga Ram Public School located at Old Delhi-Gurgaon Road, Kapashera, New Delhi-110037, comprised of ground plus two upper floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2017/SZ/907 Dated 23/06/2017. The premises was re-inspected by the officer concerned by this department on 20/02/2020 in the presence of Mr. Vijay Pal (Manager) of the school and found that the fire prevention and fire safety requirements have deemed complied in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 as mentioned below.

Issued on 18/03/2020 at New Delhi by



(S.S. Tuli)

Dy. Chief Fire Officer
Tel. 011-26189168



Copy to: -

1. The Principal, Rao Ganga Ram Public School, Old Delhi Gurgaon Road, Kapashera, New Delhi-110037
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety and means of evacuation facilities non-functional shall be the responsibility of management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire-fighting system and mock evacuation drill be conducted at regular interval and record maintained..
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.